

Wyniki - Grzejniki

Pom.	Typ grz.	n	L	Qobl	Qwym	Qrz	Qdef	Agrz	tz	dt	AG	G
		[el.]	[m]	[W]	[W]	[W]	[W]		[°C]	[K]		[kg/s]
13	CV11-60	8	0.80	736	736	736	0	1.000	70.00	19.99	1.00	0.00880
11	MUN12 05	1	0.50	287	287	316	-29	1.000	70.00	22.05	1.00	0.00343
9	MUN17 06	1	0.60	535	535	541	-6	1.000	70.00	20.22	1.00	0.00640
7	MUN17 08	1	0.80	626	626	689	-63	1.000	70.00	22.03	1.00	0.00749

Wyniki - Nastawy

Typ	Pom.	Symbol	Nastawa	Aut.	dn	G	Kv	dP	Lokalizacja elementu
					[mm]	[kg/s]	[m3/h]	[Pa]	
Z	11	RA-N-P	4	0.35	15	0.003	0.217	339	Gałązka grzejnika dn 15
Z	9	RA-N-P	6	0.36	15	0.006	0.400	348	Gałązka grzejnika dn 15
Z	7	RA-N-P	6.5	0.41	15	0.007	0.439	394	Gałązka grzejnika dn 15
Z	13	101 80 80	5	0.47	15	0.009	0.479	454	Zawór w grzejniku